

Triggered Source Monitoring and Reporting Violation: Ground Water Rule

Crescent Heights Water Supply; PWS #1070016 failed to collect the required number of triggered source bacteriological samples for fecal indicator monitoring of the ground water system during **September 2014**. This monitoring is required by the Texas Commission on Environmental Quality's "Drinking Water Standards" and the federal "Safe Drinking Water Act," Public Law 95-523.

Triggered source samples are used to monitor water quality and indicate if the water is free of fecal indicator bacteria. Following a positive routine total coliform result in our distribution system, our water system is required to submit one triggered source sample for every active ground water well. Failure to collect all required triggered source samples is a violation of the monitoring requirements and we are required to notify you of this violation.

If you have any questions regarding this violation, you may contact **Crescent Heights Water Supply** at **903.677.3946**.

Note: This violation was brought to the attention of Crescent Heights Water Supply September 3, 2015. Crescent Heights Water Supply submitted a raw water sample for the one water well that failed the previous bacteriological testing; however, Crescent Heights Water Supply failed to submit additional samplings for the remaining three water wells. After receiving notification from the Texas Commission on Environmental Quality, Crescent Heights Water Supply followed up with the required water samples on all four wells on October 6, 2015. All four samples submitted were found to be in compliance with TCEQ requirements.